

IEC 61850 Certificate - IEC 61850 Certificate #2683

750-8202/025-001 Remote Terminal Unit [WAGO Kontakttechnik GmbH & Co. KG]

07/08/2021 04:49 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	10060753-INC 17-2825
61850 Edition:	Edition 2	Certificate Hash:	DAC363DF1054B9C2428797B339652F 24DDEAD9B71F1914EC2B2BBF5620B 18ACA
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	WAGO Kontakttechnik GmbH & Co. KG	Vendor Artifact Hash:	
Address:	Hansastraße 27 32423 Minden, Germany	Umbrella Organization:	
Product:	750-8202/025-001 Remote Terminal Unit	Optional Reservation Test:	No
HW Version:	04	Serial Number:	
SW Version:	3.3.8	Publisher Legacy Variants:	
Key Words:	RTU	Publisher Preferred Rates:	
Test Procedure Version:	1.0	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Substitution (B3), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	12/08/2017	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:49 PM - Herbert Falk

- File 17-2825_DNVGL_WAGO_750_ServerEd2_Certificate.pdf added

Files

17-2825_DNVGL_WAGO_750_ServerEd2_Certificate.pdf	89.2 KB	07/08/2021	Herbert Falk
--	---------	------------	--------------