

# IEC 61850 Certificate - IEC 61850 Certificate #2684

## INGEPAC EF PB Merging Unit [Ingeteam Power Technology, S.A.]

07/08/2021 04:49 PM - Herbert Falk

<b>Status:</b>	Approved	<b>Test Document:</b>	
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	10071516-INC 17-2904
<b>61850 Edition:</b>	Edition 1	<b>Certificate Hash:</b>	554D6522FEB2C695D003EB159A0D9D 4DE44AC23F7DD2D002326D657E87A4 3DAF
<b>61850 Tested Aspects:</b>	Merging Unit	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	Ingeteam Power Technology, S.A.	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	Power Grid Automation - PGA Parque Tecnológico de Bizkaia, Edificio 110 48170 Zamudio, Bizkaia Spain	<b>Umbrella Organization:</b>	
<b>Product:</b>	INGEPAC EF PB Merging Unit	<b>Optional Reservation Test:</b>	No
<b>HW Version:</b>	PB0AEGXXXXXEFA-L-A-A-A-A-AEF E	<b>Serial Number:</b>	
<b>SW Version:</b>	0.5.1.7	<b>Publisher Legacy Variants:</b>	F4000S1I4U4, F4800S1I4U4
<b>Key Words:</b>	Merging Unit	<b>Publisher Preferred Rates:</b>	
<b>Test Procedure Version:</b>	1.1	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Sampled Value Publish (11a)	<b>Subscriber Legacy Variants:</b>	
<b>Certificate/Result Reviewer:</b>	bruce.muschlitz	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	12/11/2017	<b>Subscriber Preferred Rates:</b>	
<b>Standards Tested:</b>	61850-6, 61850-7-2, 61850-9-2, UCAIug 9-2LE		
<b>Current Test Lab Name:</b>	DNV Netherlands (A)		
<b>Description</b> This certificate and its information was migrated from a previous database			

### History

#### #1 - 07/08/2021 04:49 PM - Herbert Falk

- File 17-2904\_DNVGL\_Ingeteam\_IngepacEFPB\_92LE\_Certificate.pdf added

#### #2 - 06/13/2022 03:09 PM - Bruce Muschlitz

- Address updated

- Publisher Legacy Variants F4000S1I4U4, F4800S1I4U4 added

### Files

17-2904_DNVGL_Ingeteam_IngepacEFPB_92LE_Certificate.pdf	89.6 KB	07/08/2021	Herbert Falk
---	---------	------------	--------------