

# IEC 61850 Certificate - IEC 61850 Certificate #2685

## JVG Smart GW (Gateway) [JVG Co., Ltd.]

07/08/2021 04:49 PM - Herbert Falk

<b>Status:</b>	Approved	<b>Certificate Name:</b>	2017TS03185
<b>Priority:</b>	Normal	<b>Certificate Hash:</b>	416B1CB73AF8DEA0465529222C41B2 F7EEAF7177EA69F00E6B4FC26B57A1 DC55
<b>61850 Edition:</b>	Edition 1	<b>Vendor Artifact File Name:</b>	
<b>61850 Tested Aspects:</b>	Client	<b>Vendor Artifact Hash:</b>	
<b>Company:</b>	JVG Co., Ltd.	<b>Umbrella Organization:</b>	
<b>Address:</b>	11, Neungwon-ro 10beon-gil, Mohyeon-myeon Cheoin-gu, Yongin-si, Gyeonggi, Republic of Korea	<b>Optional Reservation Test:</b>	No
<b>Product:</b>	JVG Smart GW (Gateway)	<b>Serial Number:</b>	
<b>HW Version:</b>	HP Z420 Workstation, Win7 Pro 64	<b>Publisher Legacy Variants:</b>	
<b>SW Version:</b>	1.3	<b>Publisher Preferred Rates:</b>	
<b>Key Words:</b>	Gateway	<b>Publisher Preferred Variants:</b>	
<b>Test Procedure Version:</b>	1.1	<b>Subscriber Legacy Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), SBO Control (12b), Setting Group (B4), Setting Group Definition (B4+), Time Synchronization (B13), Unbuffered Reporting (B5)	<b>Subscriber Preferred Variants:</b>	
<b>Certificate/Result Reviewer:</b>	bruce.muschlitz	<b>Subscriber Preferred Rates:</b>	
<b>Approval Date:</b>	12/14/2017	<b>Product Variants:</b>	
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	Korea Electrotechnology Research Institute (A)		
<b>Test Document:</b>			

### Description

This certificate and its information was migrated from a previous database

### History

#1 - 07/08/2021 04:49 PM - Herbert Falk

- File 2017TS03185\_JVG\_JVG Smart GW\_Client1.0\_KERI.pdf added

### Files

2017TS03185_JVG_JVG Smart GW_Client1.0_KERI.pdf	2.57 MB	07/08/2021	Herbert Falk
---	---------	------------	--------------