

IEC 61850 Certificate - IEC 61850 Certificate #2689

PACS-5911 HV Transmission Line Protectio [Wiscom System Co., Ltd.]

07/08/2021 04:50 PM - Herbert Falk

Status:	Approved	
Priority:	Normal	
61850 Edition:	Edition 2	Certificate Name: D 17 12 03194 001
61850 Tested Aspects:	Server	Certificate Hash: 8EF7A1FD9C3D008949E72B806C929A EFABF1110A5FCB000D63D48A6F1F03 F586
Company:	Wiscom System Co., Ltd.	Vendor Artifact File Name:
Address:	No. 100 Jiangjun Road Jiangning Development Zone, Jiangsu 211100 Nanjing China	Vendor Artifact Hash:
Product:	PACS-5911 HV Transmission Line Protectio	Umbrella Organization:
HW Version:		Optional Reservation Test: No
SW Version:	1.00	Serial Number:
Key Words:	Distance, Protection, Relay	Publisher Legacy Variants:
Test Procedure Version:	1.0	Publisher Preferred Rates:
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Service Tracking (B15), Setting Group (B4), Setting Group Definition (B4+), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	Publisher Preferred Variants:
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Legacy Variants:
Approval Date:	01/02/2018	Subscriber Preferred Variants:
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	Subscriber Preferred Rates:
Current Test Lab Name:	TUV SUD China Ltd (A)	Product Variants:
Test Document:		Time Activated Control:
Description This certificate and its information was migrated from a previous database		

History

#1 - 07/08/2021 04:50 PM - Herbert Falk

- File 17-D 17 12 03194 001-Wiscom-PACS-5911_IEC61850Ed2-Server-Certificate.p added

Files

17-D 17 12 03194 001-Wiscom-PACS-5911_IEC61850Ed2-Server-Certificate.pdf	07/08/2021	Herbert Falk
--	------------	--------------