

# IEC 61850 Certificate - IEC 61850 Certificate #2692

## SSP-500 Smart System Protection Control [NARI Technology Co., Ltd.]

07/08/2021 04:50 PM - Herbert Falk

|  |   |                                       |  |
|--|---|---------------------------------------|--|
| <b>Status:</b>   | Approved  | <b>Test Document:</b>                 |  |
| <b>Priority:</b>   | Normal  | <b>Certificate Name:</b>              | D 18 02 80863 056  |
| <b>61850 Edition:</b>  | Edition 2   | <b>Certificate Hash:</b>              | E8F1D1682BB4E81452B511A97F30BA<br>155FAF4314C12F8D1A0587211D3ED4<br>D978 |
| <b>61850 Tested Aspects:</b>   | Server  | <b>Vendor Artifact File Name:</b>     |  |
| <b>Company:</b>  | NARI Technology Co., Ltd.   | <b>Vendor Artifact Hash:</b>          |  |
| <b>Address:</b>  | NARI Technology CO., Ltd.<br>No.19, Chengxin Avenue,<br>Jiangning District, 210000, Nanjing,<br>People's Republic of China  | <b>Umbrella Organization:</b>         |  |
| <b>Product:</b>  | SSP-500 Smart System Protection Control   | <b>Optional Reservation Test:</b>     | No   |
| <b>HW Version:</b>   |   | <b>Serial Number:</b>                 |  |
| <b>SW Version:</b>   | 1.00  | <b>Publisher Legacy Variants:</b>     |  |
| <b>Key Words:</b>  |   | <b>Publisher Preferred Rates:</b>     |  |
| <b>Test Procedure Version:</b>   | 1.0   | <b>Publisher Preferred Variants:</b>  |  |
| <b>IEC 61850 Blocks Certified:</b>   | Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Setting Group (B4), Setting Group Definition (B4+), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5) | <b>Subscriber Legacy Variants:</b>    |  |
| <b>Certificate/Result Reviewer:</b>  | bruce.muschlitz   | <b>Subscriber Preferred Variants:</b> |  |
| <b>Approval Date:</b>  | 02/23/2018  | <b>Subscriber Preferred Rates:</b>    |  |
| <b>Standards Tested:</b>   | 61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1  |                                       |  |
| <b>Current Test Lab Name:</b>  | TUV SUD China Ltd (A)   |                                       |  |
| <b>Description</b>   |   |                                       |  |
| This certificate and its information was migrated from a previous database |   |                                       |  |

### History

#1 - 07/08/2021 04:50 PM - Herbert Falk

- File 18-D 18 02 80863 056-NRWD-SSP-500\_IEC61850Ed2-Server-Certificate.pdf added

### Files

18-D 18 02 80863 056-NRWD-SSP-500\_IEC61850Ed2-Server-Certificate.pdf

07/08/2021

Herbert Falk