

# IEC 61850 Certificate - IEC 61850 Certificate #2693

## MP48 E+++ Remote Terminal Unit [SELESOFT]

07/08/2021 04:50 PM - Herbert Falk

<b>Status:</b>	Approved	<b>Certificate Name:</b>	10069557-INC 17-2869
<b>Priority:</b>	Normal	<b>Certificate Hash:</b>	55BC671A0B202078A73CBA584B8CA2 5332E15D8A3F20E7D68E934D104C1D 6515
<b>61850 Edition:</b>	Edition 1	<b>Vendor Artifact File Name:</b>	
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact Hash:</b>	
<b>Company:</b>	SELESOFT	<b>Umbrella Organization:</b>	
<b>Address:</b>	Via De Marini 1 16149 Genova Italy	<b>Optional Reservation Test:</b>	No
<b>Product:</b>	MP48 E+++ Remote Terminal Unit	<b>Serial Number:</b>	
<b>HW Version:</b>	FB1-000012-BA	<b>Publisher Legacy Variants:</b>	
<b>SW Version:</b>	IEC61850-server 2.0.1	<b>Publisher Preferred Rates:</b>	
<b>Key Words:</b>	RTU	<b>Publisher Preferred Variants:</b>	
<b>Test Procedure Version:</b>	3.04	<b>Subscriber Legacy Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), SBO Control (12b), Unbuffered Reporting (B5)	<b>Subscriber Preferred Variants:</b>	
<b>Certificate/Result Reviewer:</b>	bruce.muschlitz	<b>Subscriber Preferred Rates:</b>	
<b>Approval Date:</b>	03/01/2018	<b>Product Variants:</b>	
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	DNV Netherlands (A)		
<b>Test Document:</b>			

### Description

This certificate and its information was migrated from a previous database

### History

#1 - 07/08/2021 04:50 PM - Herbert Falk

- File 17-2869\_DNVGL\_SoftEco\_SeleSoft-MP48\_ServerEd1\_Certificate.pdf added

### Files

17-2869\_DNVGL\_SoftEco\_SeleSoft-MP48\_ServerEd1\_Certificate.pdf 86.3 KB

07/08/2021

Herbert Falk