

IEC 61850 Certificate - IEC 61850 Certificate #2694

MP48 E+++ Remote Terminal Unit [SELESOFT]

07/08/2021 04:50 PM - Herbert Falk

Status:	Approved	
Priority:	Normal	
61850 Edition:	Edition 1	Certificate Name: 10069557-INC 18-2205
61850 Tested Aspects:	Client	Certificate Hash: F32F145B100397F0FE3488D2946AD78 C8A73CBF72F40522E685E6CAC26B9F F9A
Company:	SELESOFT	Vendor Artifact File Name:
Address:	Via De Marini 1 16149 Genova Italy	Vendor Artifact Hash:
Product:	MP48 E+++ Remote Terminal Unit	Umbrella Organization:
HW Version:		Optional Reservation Test: No
SW Version:	IEC61850-client 2.0.1	Serial Number:
Key Words:	RTU	Publisher Legacy Variants:
Test Procedure Version:	1.1	Publisher Preferred Rates:
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), SBO Control (12b), Setting Group (B4), Unbuffered Reporting (B5)	Publisher Preferred Variants:
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Legacy Variants:
Approval Date:	03/07/2018	Subscriber Preferred Variants:
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	Subscriber Preferred Rates:
Current Test Lab Name:	DNV Netherlands (A)	Product Variants:
Test Document:		Time Activated Control:
Description This certificate and its information was migrated from a previous database		

History

#1 - 07/08/2021 04:50 PM - Herbert Falk

- File 18-2205 DNVGL SELESOFT MP48 ClientEd1 Certificate.pdf added

Files

18-2205 DNVGL SELESOFT MP48 ClientEd1 Certificate.pdf	86.9 KB	07/08/2021	Herbert Falk
---	---------	------------	--------------