

# IEC 61850 Certificate - IEC 61850 Certificate #2695

ekor.rci [Ormazabal]

07/08/2021 04:50 PM - Herbert Falk

<b>Status:</b>	Approved	<b>Test Document:</b>	
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	B43-17-AM
<b>61850 Edition:</b>	Edition 2	<b>Certificate Hash:</b>	BFD845228AD61BA23ED28DF54A50B F0C0BB9DCE520C6EB352C26185C15 54A5C9
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	Ormazabal	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	Ormazabal Protection & Automation S.L.U. Barrio basauntz 2 48140, Igorre (Bizkaia) Spain	<b>Umbrella Organization:</b>	
<b>Product:</b>	ekor.rci	<b>Optional Reservation Test:</b>	No
<b>HW Version:</b>	rev 01	<b>Serial Number:</b>	
<b>SW Version:</b>	7.11	<b>Publisher Legacy Variants:</b>	
<b>Key Words:</b>	Breaker, Protection	<b>Publisher Preferred Rates:</b>	
<b>Test Procedure Version:</b>	1.0	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), Time Synchronization (B13), Unbuffered Reporting (B5)	<b>Subscriber Legacy Variants:</b>	
<b>Certificate/Result Reviewer:</b>	bruce.muschlitz	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	03/09/2018	<b>Subscriber Preferred Rates:</b>	
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	Tecnalía (A)		

## Description

This certificate and its information was migrated from a previous database

## History

#1 - 07/08/2021 04:50 PM - Herbert Falk

- File CertificateServerEd2Revision1.0(TPCL\_1p2p4) Tecnalía\_Ormazabal B43-17- added

## Files

CertificateServerEd2Revision1.0(TPCL\_1p2p4) Tecnalía\_Ormazabal B43-17.pdf 07/08/2021 Herbert Falk