

IEC 61850 Certificate - IEC 61850 Certificate #2697

MiCOM P40 Agile P645 Transformer Protect [GE Power]

07/08/2021 04:50 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	50745.6645.801
61850 Edition:	Edition 1	Certificate Hash:	F658A377290D7DAEFD5F31616F2DFB 32D04159683D137EAC2440A1B3EB14 B7F0
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	GE Power	Vendor Artifact Hash:	
Address:	St. Leonards Building, Redhill Business Park Stafford, UK, ST16 1WT	Umbrella Organization:	
Product:	MiCOM P40 Agile P645 Transformer Protect	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	07	Publisher Legacy Variants:	
Key Words:	Differential, Protection, Relay	Publisher Preferred Rates:	
Test Procedure Version:	3.2	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	03/15/2018	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Grid Automation Laboratories (B)		
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:50 PM - Herbert Falk

- File 50745.6645.801_GE_P645_V7_Edition1_Certificate.pdf added

#2 - 08/04/2021 09:38 AM - Herbert Falk

- Current Test Lab Name changed from UK Grid Solutions Ltd (B) to Grid Automation Laboratories (B)

Files

50745.6645.801_GE_P645_V7_Edition1_Certificate.pdf	4.2 MB	07/08/2021	Herbert Falk
--	--------	------------	--------------