

IEC 61850 Certificate - IEC 61850 Certificate #2703

iDP-110 110kV Integrated Intelligent Con [BEIJING DEVOTE RELAY PROTECTION AUTOMATION TECHNOLOGY CO.,LTD.]

07/08/2021 04:50 PM - Herbert Falk

Status:	Approved	Certificate Name:	2017PUCA0007
Priority:	Normal	Certificate Hash:	79DBF12532FB248F964092F586700C2 D54F0881E389B177B9FF0FC565CE2C F60
61850 Edition:	Edition 1	Vendor Artifact File Name:	
61850 Tested Aspects:	Server	Vendor Artifact Hash:	
Company:	BEIJING DEVOTE RELAY PROTECTION AUTOMATION TECHNOLOGY CO.,LTD.	Umbrella Organization:	
Address:	No.17 JuYuan Middle Road, JuYuan Industrial Zone of MaPo, ShunYi, Beijing	Optional Reservation Test:	No
Product:	iDP-110 110kV Integrated Intelligent Con	Serial Number:	
HW Version:		Publisher Legacy Variants:	
SW Version:	0100	Publisher Preferred Rates:	
Key Words:	Protection, Relay	Publisher Preferred Variants:	
Test Procedure Version:	3.03	Subscriber Legacy Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), Setting Group (B4), Setting Group Definition (B4+), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Preferred Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Rates:	
Approval Date:	03/18/2018	Product Variants:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Xuchang KETOP Testing Research Institute Co.(A)		
Test Document:			

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:50 PM - Herbert Falk

- File Beijing_Devote_iDP-110_0100_110kV Integrated Intelligent Control Device_2017PUCA0007_KETOP.pdf added

Files

Beijing_Devote_iDP-110_0100_110kV Integrated Intelligent Control Device_2017PUCA0007_KETOP.pdf

Herbert Falk