

IEC 61850 Certificate - IEC 61850 Certificate #2706

NSA-951T5-G Transformer Protection Relay [INTEGRATED ELECTRONIC SYSTEMS LAB CO., LTD.]

07/08/2021 04:50 PM - Herbert Falk

Status:	Approved	Certificate Name:	2017PUCA0001
Priority:	Normal	Certificate Hash:	7455FFEBEF42626076FF7423517C2E5 A09F7B3FA71359437A0B4D8FF8A11A 503
61850 Edition:	Edition 1	Vendor Artifact File Name:	
61850 Tested Aspects:	Server	Vendor Artifact Hash:	
Company:	INTEGRATED ELECTRONIC SYSTEMS LAB CO., LTD.	Umbrella Organization:	
Address:	No.1677 Kehang Road, Jinan, Shandong, China	Optional Reservation Test:	No
Product:	NSA-951T5-G Transformer Protection Relay	Serial Number:	
HW Version:		Publisher Legacy Variants:	
SW Version:	V1.00	Publisher Preferred Rates:	
Key Words:	Differential, Protection, Relay	Publisher Preferred Variants:	
Test Procedure Version:	3.03	Subscriber Legacy Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), Setting Group (B4), Setting Group Definition (B4+), Substitution (B3), Unbuffered Reporting (B5)	Subscriber Preferred Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Rates:	
Approval Date:	03/19/2018	Product Variants:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Xuchang KETOP Testing Research Institute Co.(A)		
Test Document:			

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:50 PM - Herbert Falk

- File INTEGRATED ELECTRONIC SYSTEMS LAB CO., LTD._ NSA-951T5-G_V1.00_Line Tr added

Files

INTEGRATED ELECTRONIC SYSTEMS LAB CO., LTD._ NSA-951T5-G_V1.00_Line Tr added 07/08/2021

Herbert Falk