

IEC 61850 Certificate - IEC 61850 Certificate #2707

XDL-621 Line Current Differential Protec [XD-GE AUTOMATION CO.,LTD.]

07/08/2021 04:50 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	2017PUCA0013
61850 Edition:	Edition 1	Certificate Hash:	AE2841DD38D15A623A9B83F2F60B13 C3042E2DC9A14F118A16ECE70A1C58 A791
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	XD-GE AUTOMATION CO.,LTD.	Vendor Artifact Hash:	
Address:	No. 101, Fengcheng 6 Road, Economic and Technological Development Zone, Xi'an, Shaanxi, China	Umbrella Organization:	
Product:	XDL-621 Line Current Differential Protec	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	V0.16	Publisher Legacy Variants:	
Key Words:	Differential, Protection, Relay	Publisher Preferred Rates:	
Test Procedure Version:	3.03	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Setting Group (B4), Setting Group Definition (B4+), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	03/19/2018	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Xuchang KETOP Testing Research Institute Co.(A)		

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:50 PM - Herbert Falk

- File XD-GE AUTOMATION CO.,LTD._ XDL-621 Line Current Differential Protectio added

Files

XD-GE AUTOMATION CO.,LTD._ XDL-621 Line Current Differential Protec.pdf 06 KB 07/08/2021

Herbert Falk