

IEC 61850 Certificate - IEC 61850 Certificate #2711

NeoPMS SA Operating Device [NEOPIS Co., Ltd.]

07/08/2021 04:51 PM - Herbert Falk

Status:	Approved	
Priority:	Normal	
61850 Edition:	Edition 1	Certificate Name: 2018TS00415
61850 Tested Aspects:	Client	Certificate Hash: A839795F62710BD3079D38E10464FD0E5D1E3F79B624881C56D050DDB347F888
Company:	NEOPIS Co., Ltd.	Vendor Artifact File Name:
Address:	1703-A-dong, Pyeongchon Smart Bay, Bulmal-ro 123, Anyang-si, Gyeonggi-do, Republic of Korea	Vendor Artifact Hash:
Product:	NeoPMS SA Operating Device	Umbrella Organization:
HW Version:	HP Z640 Workstation, WinSrv 2012	Optional Reservation Test: No
SW Version:	7.50	Serial Number:
Key Words:	Comm	Publisher Legacy Variants:
Test Procedure Version:	1.1	Publisher Preferred Rates:
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), SBO Control (12b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Publisher Preferred Variants:
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Legacy Variants:
Approval Date:	03/25/2018	Subscriber Preferred Variants:
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	Subscriber Preferred Rates:
Current Test Lab Name:	Korea Electrotechnology Research Institute (A)	Product Variants:
Test Document:		Time Activated Control:
Description This certificate and its information was migrated from a previous database		

History

#1 - 07/08/2021 04:51 PM - Herbert Falk

- File 2018TS00415_Neopis_NeoPMS_Client1.0_KERI.pdf added

Files

2018TS00415_Neopis_NeoPMS_Client1.0_KERI.pdf	2.38 MB	07/08/2021	Herbert Falk
--	---------	------------	--------------