

IEC 61850 Certificate - IEC 61850 Certificate #2715

FOX612 with TEG01 IEC61850 interface [ABB Switzerland Ltd.]

07/08/2021 04:51 PM - Herbert Falk

Status:	Approved	
Priority:	Normal	
61850 Edition:	Edition 2	Test Document:
61850 Tested Aspects:	Server	Certificate Name: 1KHL050117
Company:	ABB Switzerland Ltd.	Certificate Hash: CB7F6EFBA33ABB46E67CD32CB83C3 1A3818973E7BC6AEC5180DFE051842 21356
Address:	Bruggerstrasse 72 Power Grids CH-5400 Baden/Switzerland	Vendor Artifact File Name:
Product:	FOX612 with TEG01 IEC61850 interface	Vendor Artifact Hash:
HW Version:		Umbrella Organization:
SW Version:	R1A11	Optional Reservation Test: No
Key Words:	Comm, Gateway	Serial Number:
Test Procedure Version:	1.0	Publisher Legacy Variants:
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Unbuffered Reporting (B5)	Publisher Preferred Rates:
Certificate/Result Reviewer:	bruce.muschlitz	Publisher Preferred Variants:
Approval Date:	04/04/2018	Subscriber Legacy Variants:
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	Subscriber Preferred Variants:
Current Test Lab Name:	ABB Switzerland Ltd. (B)	Subscriber Preferred Rates:
Description This certificate and its information was migrated from a previous database		

History

#1 - 07/08/2021 04:51 PM - Herbert Falk

- File 1KHL050117_IEC61850ConformanceCertificate_ServerEd2_FOX612TEGO1_R1A11. added

Files

1KHL050117_IEC61850ConformanceCertificate_ServerEd2_FOX612TEGO1_R1A11.pdf	07/08/2021	Herbert Falk
---	------------	--------------