

# IEC 61850 Certificate - IEC 61850 Certificate #2717

## Easergy MiCOM P741 Busbar Protection Rel [Schneider Electric Industries SAS]

07/08/2021 04:51 PM - Herbert Falk

<b>Status:</b>	Approved	<b>Test Document:</b>	
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	10074098-INC 18-2062
<b>61850 Edition:</b>	Edition 2	<b>Certificate Hash:</b>	494F584D7C2EDFAE22F3EBA645078F B1AD52CA4C51E736ED3B879886F5B A1C7A
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	Schneider Electric Industries SAS	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	35 rue Joseph Monier 92500 Rueil-Malmaison, France	<b>Umbrella Organization:</b>	Schneider Electric
<b>Product:</b>	Easergy MiCOM P741 Busbar Protection Rel	<b>Optional Reservation Test:</b>	No
<b>HW Version:</b>	M	<b>Serial Number:</b>	
<b>SW Version:</b>	B1	<b>Publisher Legacy Variants:</b>	
<b>Key Words:</b>	Protection, Relay	<b>Publisher Preferred Rates:</b>	
<b>Test Procedure Version:</b>	1.0	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	<b>Subscriber Legacy Variants:</b>	
<b>Certificate/Result Reviewer:</b>	bruce.muschlitz	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	04/05/2018	<b>Subscriber Preferred Rates:</b>	
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	DNV Netherlands (A)		
<b>Description</b>			
This certificate and its information was migrated from a previous database			

### History

#1 - 07/08/2021 04:51 PM - Herbert Falk

- File 18-2062\_DNVGL\_Schneider Electric\_P741\_ServerEd2\_Certificate.pdf added

#2 - 07/09/2021 08:01 AM - Herbert Falk

- Umbrella Organization set to Schneider Electric

#3 - 07/09/2021 09:09 AM - Herbert Falk

- Umbrella Organization deleted (Schneider Electric)

#4 - 07/09/2021 09:11 AM - Herbert Falk

**Files**

---

18-2062_DNVGL_Schneider Electric_P741_ServerEd2_Certificate.pdf90.8 KB	07/08/2021	Herbert Falk
--	------------	--------------