

IEC 61850 Certificate - IEC 61850 Certificate #2720

Easergy MiCOM P438 Rail Catenary Protect [Schneider Electric Industries SAS]

07/08/2021 04:51 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	10071281-INC 18-2122
61850 Edition:	Edition 2	Certificate Hash:	E158245EDBF6A185F5B1A88CED240A 424258F22642EB0AB594A987732C16B 0E3
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Schneider Electric Industries SAS	Vendor Artifact Hash:	
Address:	35 rue Joseph Monier 92500 Rueil-Malmaison, France	Umbrella Organization:	Schneider Electric
Product:	Easergy MiCOM P438 Rail Catenary Protect	Optional Reservation Test:	No
HW Version:	418	Serial Number:	
SW Version:	P438-661-251	Publisher Legacy Variants:	
Key Words:	Protection, Relay	Publisher Preferred Rates:	
Test Procedure Version:	1.0	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	04/20/2018	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:51 PM - Herbert Falk

- File 18-2122_DNVGL_Schneider Electric_P438_ServerEd2_Certificate.pdf added

#2 - 07/09/2021 08:01 AM - Herbert Falk

- Umbrella Organization set to Schneider Electric

#3 - 07/09/2021 09:10 AM - Herbert Falk

- Umbrella Organization deleted (Schneider Electric)

#4 - 07/09/2021 09:11 AM - Herbert Falk

Files

18-2122_DNVGL_Schneider Electric_P438_ServerEd2_Certificate.pdf 120 KB	07/08/2021	Herbert Falk
--	------------	--------------