

IEC 61850 Certificate - IEC 61850 Certificate #2725

AC500-PM5675 [ABB Automation GmbH]

07/08/2021 04:51 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	ZE 18 05 45204 004 B
61850 Edition:	Edition 1	Certificate Hash:	AFB4152BD1E8F66DE3FA89E1544BD3 AB57015708EAF1BBBA84D240D54102 2640
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	ABB Automation GmbH	Vendor Artifact Hash:	
Address:	Epperheimer Strasse 82 69123 Heidelberg Deutschland	Umbrella Organization:	
Product:	AC500-PM5675	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	4.0.3 B0075	Publisher Legacy Variants:	
Key Words:	Bay Controller	Publisher Preferred Rates:	
Test Procedure Version:	3.03	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Substitution (B3), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	05/07/2018	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	TUV SUD Germany (A)		

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:51 PM - Herbert Falk

- File UCA ZE 18 05 45204 004_B_ABB_AC500-PM5650_IEC61850Ed2-Server-Certifica added

Files

UCA ZE 18 05 45204 004_B_ABB_AC500-PM5650_IEC61850Ed2-Server-Certificate.pdf 07/08/2021

Herbert Falk