

IEC 61850 Certificate - IEC 61850 Certificate #2729

Excount III Surge Arrester Monitor [ABB AB]

07/08/2021 04:51 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	ZE 18 05 04794 001
61850 Edition:	Edition 2	Certificate Hash:	435E234194F3A5504916C120316C8E0 0A56962F754E6D829EB59FA5E41AA4 380
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	ABB AB	Vendor Artifact Hash:	
Address:	Lyviksvagen 4 771 80 Ludvika, SWEDEN	Umbrella Organization:	
Product:	Excount III Surge Arrester Monitor	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	1.0	Publisher Legacy Variants:	
Key Words:	Measurement	Publisher Preferred Rates:	
Test Procedure Version:	1.0	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Enhanced SBO Control (12d)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	05/16/2018	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	TUV SUD Germany (A)		
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:51 PM - Herbert Falk

- File UCA_18 ZE 05 04794 001_ABB_EXCOUNT III_IEC61850Ed2-Server-Certificate. added

Files

UCA_18 ZE 05 04794 001_ABB_EXCOUNT III_IEC61850Ed2-Server-Certificate.pdf 07/08/2021

Herbert Falk