

# IEC 61850 Certificate - IEC 61850 Certificate #2730

## SMD-K010 Realtime Operation Information [Sanion Co., Ltd.]

07/08/2021 04:51 PM - Herbert Falk

<b>Status:</b>	Approved	<b>Test Document:</b>	
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	18-014824-01-2
<b>61850 Edition:</b>	Edition 1	<b>Certificate Hash:</b>	A0EAC5F06B5BADDFFEE0689358B1A4 8017AEFFF6016D2823D1DCBCD510B 97D73E
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	Sanion Co., Ltd.	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	13, Geomdan-ro, 114beon-gil, Seo-gu, Incheon, Republic of Korea, 22663	<b>Umbrella Organization:</b>	
<b>Product:</b>	SMD-K010 Realtime Operation Information	<b>Optional Reservation Test:</b>	No
<b>HW Version:</b>	Windows Server 2012 R2	<b>Serial Number:</b>	
<b>SW Version:</b>	1.0	<b>Publisher Legacy Variants:</b>	
<b>Key Words:</b>	Comm, RTU	<b>Publisher Preferred Rates:</b>	
<b>Test Procedure Version:</b>	3.03	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), Time Synchronization (B13), Unbuffered Reporting (B5)	<b>Subscriber Legacy Variants:</b>	
<b>Certificate/Result Reviewer:</b>	bruce.muschlitz	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	05/17/2018	<b>Subscriber Preferred Rates:</b>	
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	Korea Testing Laboratory (A)		
<b>Description</b>			
This certificate and its information was migrated from a previous database			

### History

#1 - 07/08/2021 04:51 PM - Herbert Falk

- File 18-014824-01-2\_Sanion\_SMD-K010\_Server\_Ed1\_Certification\_KTL.pdf added

### Files

18-014824-01-2\_Sanion\_SMD-K010\_Server\_Ed1\_Certification\_KTL.pdf 10 KB

07/08/2021

Herbert Falk