

IEC 61850 Certificate - IEC 61850 Certificate #2731

TSL-9r Busbar and Breaker Failure prot [ZPrAE Sp.Z o.o.]

07/08/2021 04:51 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	37001-20180108
61850 Edition:	Edition 2	Certificate Hash:	137F1BB63CD71286495FADA4C2BBA9 DDE13B7F8DD9C7F9F7ACF9FF92925 CCB2F
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	ZPrAE Sp.Z o.o.	Vendor Artifact Hash:	
Address:	41-100 Siemianowice Slaskie ul. Konopnickiej 13	Umbrella Organization:	
Product:	TSL-9r Busbar and Breaker Failure prot	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	6.2-4936	Publisher Legacy Variants:	
Key Words:	Bay Controller, Protection	Publisher Preferred Rates:	
Test Procedure Version:	1.0	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	05/17/2018	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	AMA-CERT-Lab GmbH (A)		
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:51 PM - Herbert Falk

- File CertificateServerEd2_ZPrAE_TSL9_37C001-20180108.pdf added

Files

CertificateServerEd2_ZPrAE_TSL9_37C001-20180108.pdf	1.58 MB	07/08/2021	Herbert Falk
-----------------------------------------------------	---------	------------	--------------