IEC 61850 Certificate - IEC 61850 Certificate #2733

YR-320X Protective Relay [YOUNG IN ENGINEERING CO., LTD.]

07/08/2021 04:52 PM - Herbert Falk

Status:	Approved		
Priority:	Normal		
61850 Edition:	Edition 2	**Certificate Name:**	2018TS00851
61850 Tested Aspects:	Server	**Certificate Hash:**	88C8D6E970A962CDF4EB450D001420A5D40B5F652AAD668CC3B1BDB7754F2B69
Company:	YOUNG IN ENGINEERING CO., LTD.	**Vendor Artifact File Name:**	
Address:	#113, Suntech City 474, Dunchon-daero Jungwon-gu Seongnam-si Gyeonggi-do 13229 Republic of Korea	**Vendor Artifact Hash:**	
Product:	YR-320X Protective Relay	**Umbrella Organization:**	
HW Version:		**Optional Reservation Test:**	No
SW Version:	iec61850.v1.00 , omap138. v1.00	**Serial Number:**	
Key Words:	Protection, Relay	**Publisher Legacy Variants:**	
Test Procedure Version:	1.0	**Publisher Preferred Rates:**	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	**Publisher Preferred Variants:**	
Certificate/Result Reviewer:	bruce.muschlitz	**Subscriber Legacy Variants:**	
Approval Date:	05/30/2018	**Subscriber Preferred Variants:**	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	**Subscriber Preferred Rates:**	
Current Test Lab Name:	Korea Electrotechnology Research Institute (A)	**Product Variants:**	
Test Document:			

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:52 PM - Herbert Falk

- File 2018TS00851_Youngin_YR-320X_Server2.0_KERI.pdf added

Files

2018TS00851_Youngin_YR-320X_Server2.0_KERI.pdf	2.5 MB	07/08/2021	Herbert Falk