

IEC 61850 Certificate - IEC 61850 Certificate #2733

YR-320X Protective Relay [YOUNG IN ENGINEERING CO., LTD.]

07/08/2021 04:52 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	2018TS00851
61850 Edition:	Edition 2	Certificate Hash:	88C8D6E970A962CDF4EB450D001420 A5D40B5F652AAD668CC3B1BDB7754 F2B69
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	YOUNG IN ENGINEERING CO., LTD.	Vendor Artifact Hash:	
Address:	#113, Suntech City 474, Dunchon-daero Jungwon-gu Seongnam-si Gyeonggi-do 13229 Republic of Korea	Umbrella Organization:	
Product:	YR-320X Protective Relay	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	iec61850.v1.00 , omap138. v1.00	Publisher Legacy Variants:	
Key Words:	Protection, Relay	Publisher Preferred Rates:	
Test Procedure Version:	1.0	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	05/30/2018	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Korea Electrotechnology Research Institute (A)		
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:52 PM - Herbert Falk

- File 2018TS00851_Youngin_YR-320X_Server2.0_KERI.pdf added

Files

2018TS00851_Youngin_YR-320X_Server2.0_KERI.pdf	2.5 MB	07/08/2021	Herbert Falk
--	--------	------------	--------------