

IEC 61850 Certificate - IEC 61850 Certificate #2734

T-IED 23kV Electric Protection Relay [KMData Inc.]

07/08/2021 04:52 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	2018TS01142
61850 Edition:	Edition 1	Certificate Hash:	53FACA598E249520A90D7968A299175 C70D1DCCD1A20425EA7A3A28403483 FFD
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	KMData Inc.	Vendor Artifact Hash:	
Address:	505-2, Daeryung Techno Town 1-cha 18, Gasan Digital 2-ro, Geumcheon-gu, Seoul, 08592 Republic of Korea	Umbrella Organization:	
Product:	T-IED 23kV Electric Protection Relay	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	1.00	Publisher Legacy Variants:	
Key Words:	Protection, Relay	Publisher Preferred Rates:	
Test Procedure Version:	3.1	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	06/07/2018	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Korea Electrotechnology Research Institute (A)		
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:52 PM - Herbert Falk

- File 2018TS01142_KMData_T-IED 23kV_Server1.0_KERI.pdf added

Files

2018TS01142_KMData_T-IED 23kV_Server1.0_KERI.pdf	2.36 MB	07/08/2021	Herbert Falk
--	---------	------------	--------------