

IEC 61850 Certificate - IEC 61850 Certificate #2737

UR N60 Network Stability and Synchrophas [GE Grid Automation]

07/08/2021 04:52 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	50745.6UR.802
61850 Edition:	Edition 2	Certificate Hash:	0EE0DF4E650E437A8B0D8BA0A31D8 EF6EEE3197EA86CC7A5460ECDEDC2 6C2E51
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	GE Grid Automation	Vendor Artifact Hash:	
Address:	650 Markland St. Markham, ON L6C 0M1, Canada	Umbrella Organization:	
Product:	UR N60 Network Stability and Synchrophas	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	7.70	Publisher Legacy Variants:	
Key Words:	Protection, Relay	Publisher Preferred Rates:	
Test Procedure Version:	1.0	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	06/19/2018	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Grid Automation Laboratories (B)		

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:52 PM - Herbert Falk

- File 50745.6UR.802_GE_UR_Edition2_Certificate.pdf added

#2 - 08/04/2021 09:38 AM - Herbert Falk

- Current Test Lab Name changed from UK Grid Solutions Ltd (B) to Grid Automation Laboratories (B)

Files

50745.6UR.802_GE_UR_Edition2_Certificate.pdf	4.18 MB	07/08/2021	Herbert Falk
--	---------	------------	--------------