

IEC 61850 Certificate - IEC 61850 Certificate #2738

UR N60 Network Stability and Synchrophas [GE Grid Automation]

07/08/2021 04:52 PM - Herbert Falk

Status:	Approved	
Priority:	Normal	
61850 Edition:	Edition 1	Test Document:
61850 Tested Aspects:	Server	Certificate Name: 50745.6UR.803
Company:	GE Grid Automation	Certificate Hash: 49238BD39E12F421CCD9D4B237593E D9319126D969735CAE550D0D9DA6D A35F3
Address:	650 Markland St. Markham, ON L6C OM1, Canada	Vendor Artifact File Name:
Product:	UR N60 Network Stability and Synchrophas	Vendor Artifact Hash:
HW Version:		Umbrella Organization:
SW Version:	7.70	Optional Reservation Test: No
Key Words:	Protection, Relay	Serial Number:
Test Procedure Version:	3.2	Publisher Legacy Variants:
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Publisher Preferred Rates:
Certificate/Result Reviewer:	bruce.muschlitz	Publisher Preferred Variants:
Approval Date:	06/19/2018	Subscriber Legacy Variants:
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	Subscriber Preferred Variants:
Current Test Lab Name:	Grid Automation Laboratories (B)	Subscriber Preferred Rates:
Description This certificate and its information was migrated from a previous database		

History

- #1 - 07/08/2021 04:52 PM - Herbert Falk
- File 50745.6UR.803_GE_UR_Edition1_Certificate.pdf added
- #2 - 08/04/2021 09:38 AM - Herbert Falk
- Current Test Lab Name changed from UK Grid Solutions Ltd (B) to Grid Automation Laboratories (B)

Files

50745.6UR.803_GE_UR_Edition1_Certificate.pdf	4.11 MB	07/08/2021	Herbert Falk
--	---------	------------	--------------