

# IEC 61850 Certificate - IEC 61850 Certificate #2740

## Diagnostic Unit for a Substation Total D [Hanbit EDS Co., Ltd.]

07/08/2021 04:52 PM - Herbert Falk

<b>Status:</b>	Approved	<b>Test Document:</b>	
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	18-029209-01-2
<b>61850 Edition:</b>	Edition 1	<b>Certificate Hash:</b>	212DA17482E4CD6E41BBE6F5571DD EDA58B024555A0F56E769C569E349C CA14A
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	Hanbit EDS Co., Ltd.	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	44-10 Techno 10-ro, Yuseong-gu, Daejeon 305510 Republic of Korea	<b>Umbrella Organization:</b>	
<b>Product:</b>	Diagnostic Unit for a Substation Total D	<b>Optional Reservation Test:</b>	No
<b>HW Version:</b>	Window Server 2012 R2	<b>Serial Number:</b>	
<b>SW Version:</b>	1.0	<b>Publisher Legacy Variants:</b>	
<b>Key Words:</b>	Comm, Measurement	<b>Publisher Preferred Rates:</b>	
<b>Test Procedure Version:</b>	3.03	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Enhanced SBO Control (12d), Time Synchronization (B13)	<b>Subscriber Legacy Variants:</b>	
<b>Certificate/Result Reviewer:</b>	bruce.muschlitz	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	06/22/2018	<b>Subscriber Preferred Rates:</b>	
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	Korea Testing Laboratory (A)		
<b>Description</b>			
This certificate and its information was migrated from a previous database			

### History

#1 - 07/08/2021 04:52 PM - Herbert Falk

- File 18-029209-01-2\_HanbitEDS\_HBPDS-MU\_Server\_Ed1\_Certification\_KTL.pdf added

### Files

18-029209-01-2\_HanbitEDS\_HBPDS-MU\_Server\_Ed1\_Certification\_KTL.pdf

07/08/2021

Herbert Falk