

IEC 61850 Certificate - IEC 61850 Certificate #2743

PCS-915SC BUSBAR RELAY [NR Electric Co., Ltd.]

07/08/2021 04:52 PM - Herbert Falk

Status:	Approved	
Priority:	Normal	
61850 Edition:	Edition 2	Certificate Name: 10080975-INC 18-2439
61850 Tested Aspects:	GOOSE Performance	Certificate Hash: 72FCF7F695C45C95CDD066B2A243A79C639D0E5BBC4645B5F479F01E369F FDCF
Company:	NR Electric Co., Ltd.	Vendor Artifact File Name:
Address:	69 Suyuan Avenue 211102 Nanjing China	Vendor Artifact Hash:
Product:	PCS-915SC BUSBAR RELAY	Umbrella Organization:
HW Version:	NR6106-3	Optional Reservation Test: No
SW Version:	1.00	Serial Number:
Key Words:	Differential, Protection, Relay	Publisher Legacy Variants:
Test Procedure Version:	2.5	Publisher Preferred Rates:
IEC 61850 Blocks Certified:	GOOSE Performance - No Conformance Block	Publisher Preferred Variants:
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Legacy Variants:
Approval Date:	06/22/2018	Subscriber Preferred Variants:
Standards Tested:	61850-5	Subscriber Preferred Rates:
Current Test Lab Name:	DNV Netherlands (A)	Product Variants:
Test Document:		Time Activated Control:
Description This certificate and its information was migrated from a previous database		

History

#1 - 07/08/2021 04:52 PM - Herbert Falk

- File 18-2439 DNV GL NR Electric - PCS-915S_GOOSE_PerformanceEd2_Certificate added

#2 - 08/05/2021 12:14 PM - Herbert Falk

- IEC 61850 Blocks Certified GOOSE Performance - No Conformance Block added

- IEC 61850 Blocks Certified deleted (Basic Exchange (B1))

Files

18-2439 DNV GL NR Electric - PCS-915S_GOOSE_PerformanceEd2_Certificate.pdf 07/08/2021

Herbert Falk