

IEC 61850 Certificate - IEC 61850 Certificate #2748

BE2704V019 (??2704V019) Line Relay [EKRA Research and Production Enterprise, Ltd.]

07/08/2021 04:52 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	10096707-INC 18-2526
61850 Edition:	Edition 2	Certificate Hash:	A3852CC22D6EB37F3926021572B673 B065A28EC3D4E357C88218448E8DA3 AF4D
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	EKRA Research and Production Enterprise, Ltd.	Vendor Artifact Hash:	
Address:	Yakovlev prospect, 3 428003 Cheboksary Russia	Umbrella Organization:	
Product:	BE2704V019 (??2704V019) Line Relay	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	306	Publisher Legacy Variants:	
Key Words:	Distance, Protection, Relay	Publisher Preferred Rates:	
Test Procedure Version:	1.0	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Setting Group (B4), Setting Group Definition (B4+), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	07/02/2018	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:52 PM - Herbert Falk

- File 18-2526_DNVGL_EKRA_BE2704V019_ServerEd2_Certificate.pdf added

Files

18-2526_DNVGL_EKRA_BE2704V019_ServerEd2_Certificate.pdf	129 KB	07/08/2021	Herbert Falk
---	--------	------------	--------------