IEC 61850 Certificate - IEC 61850 Certificate #2748

BE2704V019 (??2704V019) Line Relay [EKRA Research and Production Enterprise, Ltd.]

07/08/2021 04:52 PM - Herbert Falk

Status:	Approved		
Priority:	Normal		
61850 Edition:	Edition 2	**Certificate Name:**	10096707-INC 18-2526
61850 Tested Aspects:	Server	**Certificate Hash:**	A3852CC22D6EB37F3926021572B673B065A28EC3D4E357C88218448E8DA3AF4D
Company:	EKRA Research and Production Enterprise, Ltd.	**Vendor Artifact File Name:**	
Address:	Yakovlev prospect, 3 428003 Cheboksary Russia	**Vendor Artifact Hash:**	
Product:	BE2704V019 (??2704V019) Line Relay	**Umbrella Organization:**	
HW Version:		**Optional Reservation Test:**	No
SW Version:	306	**Serial Number:**	
Key Words:	Distance, Protection, Relay	**Publisher Legacy Variants:**	
Test Procedure Version:	1.0	**Publisher Preferred Rates:**	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Setting Group (B4), Setting Group Definition (B4+), Time Synchronization (B13), Unbuffered Reporting (B5)	**Publisher Preferred Variants:**	
Certificate/Result Reviewer:	bruce.muschlitz	**Subscriber Legacy Variants:**	
Approval Date:	07/02/2018	**Subscriber Preferred Variants:**	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	**Subscriber Preferred Rates:**	
Current Test Lab Name:	DNV Netherlands (A)	**Product Variants:**	
Test Document:			

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:52 PM - Herbert Falk

- File 18-2526_DNVGL_EKRA_BE2704V019_ServerEd2_Certificate.pdf added

Files

18-2526_DNVGL_EKRA_BE2704V019_ServerEd2_Certificate.pdf	129 KB	07/08/2021	Herbert Falk