

IEC 61850 Certificate - IEC 61850 Certificate #2752

SICAM A8000 CP-8050 with CI-8520 module [Siemens AG]

07/08/2021 04:52 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	10087389-INC 18-2647
61850 Edition:	Edition 2	Certificate Hash:	314FA8C4576D4375552357BE2880EE C18F4D8F941E7C3D028CC630D9B06F ECA3
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Siemens AG	Vendor Artifact Hash:	
Address:	IC SG EA PRO Humboldstr. 59 90459 Nuremberg, Germany	Umbrella Organization:	
Product:	SICAM A8000 CP-8050 with CI-8520 module	Optional Reservation Test:	No
HW Version:	6MF28050AA00-BB, 6MF28520AA00-BB	Serial Number:	
SW Version:	ETI5 Rev. 03.09	Publisher Legacy Variants:	
Key Words:	RTU	Publisher Preferred Rates:	
Test Procedure Version:	1.0	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Setting Group (B4), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	07/12/2018	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:52 PM - Herbert Falk

- File 18-2647_DNVGL_Siemens_SICAM A8000_CP-8050_(ETI5_FW)_ServerEd2_Certific added

Files

18-2647_DNVGL_Siemens_SICAM A8000_CP-8050_(ETI5_FW)_ServerEd2_Certific.pdf 07/08/2021

Herbert Falk