

IEC 61850 Certificate - IEC 61850 Certificate #2753

ePOA5 Explorer Protection System Oiagnos [E5P Inc.]

07/08/2021 04:52 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	2018TS01427
61850 Edition:	Edition 1	Certificate Hash:	8E2F10A6544E7C911655066DF9ED76 2F94B038288C8DBFAAEBB200C8CC0 E3DE7
61850 Tested Aspects:	Client	Vendor Artifact File Name:	
Company:	E5P Inc.	Vendor Artifact Hash:	
Address:	Dongil Techno Town C-3209 40, 5imin-daero 365beon-gil, Dongan-gu, Anyang-si, Gyeonggi-do, Republic of Korea	Umbrella Organization:	
Product:	ePOA5 Explorer Protection System Oiagnos	Optional Reservation Test:	No
HW Version:	HP OL380 Gen9 E5-2630v4 Srv 2012	Serial Number:	
SW Version:	1.1	Publisher Legacy Variants:	
Key Words:	Measurement	Publisher Preferred Rates:	
Test Procedure Version:	1.1	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), SBO Control (12b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	07/18/2018	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Korea Electrotechnology Research Institute (A)		
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:52 PM - Herbert Falk

- File 2018TS01427_ESP_ePDAS Explorer_Client1.0_KERI.pdf added

Files

2018TS01427_ESP_ePDAS Explorer_Client1.0_KERI.pdf	1.11 MB	07/08/2021	Herbert Falk
---	---------	------------	--------------