

IEC 61850 Certificate - IEC 61850 Certificate #2756

IRF-A Feeder protection [ZIV GRID Automation S.L.]

07/08/2021 04:52 PM - Herbert Falk

Status:	Approved	
Priority:	Normal	
61850 Edition:	Edition 2	Certificate Name: 10111820-INC 18-2768
61850 Tested Aspects:	Server	Certificate Hash: C55CC19060150EFE3F6EF1A8FEB3B98D8FE6436353FDE9AAE8FFA0753FDB9CDE
Company:	ZIV GRID Automation S.L.	Vendor Artifact File Name:
Address:	Parque Tecnológico, Edificio 210-48170 Zamudio, Bizkaia Spain	Vendor Artifact Hash:
Product:	IRF-A Feeder protection	Umbrella Organization:
HW Version:	IRF-A-2A24200A000000AA10	Optional Reservation Test: No
SW Version:	0.9.0	Serial Number:
Key Words:	IOC, Protection, Relay, TOC	Publisher Legacy Variants:
Test Procedure Version:	1.0	Publisher Preferred Rates:
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Setting Group Definition (B4+), Time Synchronization (B13), Unbuffered Reporting (B5)	Publisher Preferred Variants:
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Legacy Variants:
Approval Date:	08/07/2018	Subscriber Preferred Variants:
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	Subscriber Preferred Rates:
Current Test Lab Name:	DNV Netherlands (A)	Product Variants:
Test Document:		Time Activated Control:
Description This certificate and its information was migrated from a previous database		

History

#1 - 07/08/2021 04:52 PM - Herbert Falk

- File 18-2768_DNVGL_ZIV_IRFA_IDFB_ZLFA_ServerEd2_Certificate.pdf added

Files

18-2768_DNVGL_ZIV_IRFA_IDFB_ZLFA_ServerEd2_Certificate.pdf	130 KB	07/08/2021	Herbert Falk
--	--------	------------	--------------