

# IEC 61850 Certificate - IEC 61850 Certificate #2758

## REG-D Voltage Regulator [A. Eberle GmbH & Co. KG]

07/08/2021 04:53 PM - Herbert Falk

<b>Status:</b>	Approved	<b>Certificate Name:</b>	ZE 69589 0009 A
<b>Priority:</b>	Normal	<b>Certificate Hash:</b>	8A367FD1DE1CE82215B537592B7253 5F5BF4AD88A0D9068E875D33C01CC6 F1ED
<b>61850 Edition:</b>	Edition 2	<b>Vendor Artifact File Name:</b>	
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact Hash:</b>	
<b>Company:</b>	A. Eberle GmbH & Co. KG	<b>Umbrella Organization:</b>	
<b>Address:</b>	Frankenstr. 160 90461 Nurnberg Germany	<b>Optional Reservation Test:</b>	No
<b>Product:</b>	REG-D Voltage Regulator	<b>Serial Number:</b>	
<b>HW Version:</b>		<b>Publisher Legacy Variants:</b>	
<b>SW Version:</b>	10.6.21	<b>Publisher Preferred Rates:</b>	
<b>Key Words:</b>	Measurement	<b>Publisher Preferred Variants:</b>	
<b>Test Procedure Version:</b>	1.0	<b>Subscriber Legacy Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Time Synchronization (B13), Unbuffered Reporting (B5)	<b>Subscriber Preferred Variants:</b>	
<b>Certificate/Result Reviewer:</b>	bruce.muschlitz	<b>Subscriber Preferred Rates:</b>	
<b>Approval Date:</b>	08/09/2018	<b>Product Variants:</b>	
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	TUV SUD Germany (A)		
<b>Test Document:</b>			
<b>Description</b>			
This certificate and its information was migrated from a previous database			

### History

#1 - 07/08/2021 04:53 PM - Herbert Falk

- File UCA-ZE 69589 0009A\_A-Eberle\_REG-D\_IEC61850Ed2-Server-Certificate2.pdf added

### Files

UCA-ZE 69589 0009A\_A-Eberle\_REG-D\_IEC61850Ed2-Server-Certificate2.pdf

07/08/2021

Herbert Falk