

IEC 61850 Certificate - IEC 61850 Certificate #2760

REG-DPA Regulator for Peterson Coil [A. Eberle GmbH & Co. KG]

07/08/2021 04:53 PM - Herbert Falk

Status:	Approved	Certificate Name:	ZE 69589 0009 C
Priority:	Normal	Certificate Hash:	82BD3D48E56BDAF14ACC40080F2223 04A078050CEBDE761FA221507E1851 B61F
61850 Edition:	Edition 2	Vendor Artifact File Name:	
61850 Tested Aspects:	Server	Vendor Artifact Hash:	
Company:	A. Eberle GmbH & Co. KG	Umbrella Organization:	
Address:	Frankenstr. 160 90461 Nurnberg Germany	Optional Reservation Test:	No
Product:	REG-DPA Regulator for Peterson Coil	Serial Number:	
HW Version:		Publisher Legacy Variants:	
SW Version:	10.6.21	Publisher Preferred Rates:	
Key Words:	Configurator, Measurement, Protection, Test Tool	Publisher Preferred Variants:	
Test Procedure Version:	1.0	Subscriber Legacy Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Preferred Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Rates:	
Approval Date:	08/09/2018	Product Variants:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	TUV SUD Germany (A)		
Test Document:			
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:53 PM - Herbert Falk

- File UCA-ZE 69589 0009C_A-Eberle_REG-DPA_IEC61850Ed2-Server-Certificate2.pdf added

Files

UCA-ZE 69589 0009C_A-Eberle_REG-DPA_IEC61850Ed2-Server-Certificate2.pdf 07/08/2021

Herbert Falk