

IEC 61850 Certificate - IEC 61850 Certificate #2761

GIPAM3000 Multifunctional Protection Rel [LSIS Co., Ltd.]

07/08/2021 04:53 PM - Herbert Falk

Status:	Approved	
Priority:	Normal	
61850 Edition:	Edition 1	Certificate Name: 2018TS01615
61850 Tested Aspects:	Server	Certificate Hash: CEC04AC223A0DEABD58A1AB6C9D672922F6D0EFD3385EFB4CB54A54A3C4C848
Company:	LSIS Co., Ltd.	Vendor Artifact File Name:
Address:	LS Tower, 127 LS-RO, Dongan-Gu, Anytang-Si, Gyeonggi-Do Republic of Korea	Vendor Artifact Hash:
Product:	GIPAM3000 Multifunctional Protection Rel	Umbrella Organization:
HW Version:		Optional Reservation Test: No
SW Version:	1.00	Serial Number:
Key Words:	Distance, IOC, Protection, Relay, TOC	Publisher Legacy Variants:
Test Procedure Version:	3.1	Publisher Preferred Rates:
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Publisher Preferred Variants:
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Legacy Variants:
Approval Date:	08/19/2018	Subscriber Preferred Variants:
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	Subscriber Preferred Rates:
Current Test Lab Name:	Korea Electrotechnology Research Institute (A)	Product Variants:
Test Document:		
Description This certificate and its information was migrated from a previous database		

History

#1 - 07/08/2021 04:53 PM - Herbert Falk

- File 2018TS01615_L SIS_GIPAM3000_Server1.0_KERI.pdf added

Files

2018TS01615_L SIS_GIPAM3000_Server1.0_KERI.pdf	2.73 MB	07/08/2021	Herbert Falk
--	---------	------------	--------------