

IEC 61850 Certificate - IEC 61850 Certificate #2762

GIPAM3000 Multifunctional Protection Rel [LSIS Co., Ltd.]

07/08/2021 04:53 PM - Herbert Falk

Status:	Approved	Certificate Name:	2018TS01647
Priority:	Normal	Certificate Hash:	2F2CC4031813244331B053ABC9393A A382A0257B66AF2CF62D64D3A09B09 B600
61850 Edition:	Edition 2	Vendor Artifact File Name:	
61850 Tested Aspects:	Server	Vendor Artifact Hash:	
Company:	LSIS Co., Ltd.	Umbrella Organization:	
Address:	LS Tower, 127 LS-RO, Dongan-Gu, Anytang-Si, Gyeonggi-Do Republic of Korea	Optional Reservation Test:	No
Product:	GIPAM3000 Multifunctional Protection Rel	Serial Number:	
HW Version:		Publisher Legacy Variants:	
SW Version:	1.00	Publisher Preferred Rates:	
Key Words:	Distance, IOC, Protection, Relay, TOC	Publisher Preferred Variants:	
Test Procedure Version:	1.0	Subscriber Legacy Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Preferred Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Rates:	
Approval Date:	08/20/2018	Product Variants:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Korea Electrotechnology Research Institute (A)		
Test Document:			
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:53 PM - Herbert Falk

- File 2018TS01647_L SIS_GIPAM3000_Server2.0_KERI.pdf added

Files

2018TS01647_L SIS_GIPAM3000_Server2.0_KERI.pdf	2.77 MB	07/08/2021	Herbert Falk
--	---------	------------	--------------