

IEC 61850 Certificate - IEC 61850 Certificate #2768

BHEL-BCU Bay Control Unit [Bharat Heavy Electricals Ltd.]

07/08/2021 04:53 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	MUADSASL1718C003
61850 Edition:	Edition 2	Certificate Hash:	828937749B39D217965FC3FE7C6F508 32E47CE88D909AAE664199717C8049 280
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Bharat Heavy Electricals Ltd.	Vendor Artifact Hash:	
Address:	BHEL Corporate Research & Development, Vikas Nagar, Hyderabad - 500093 INDIA	Umbrella Organization:	
Product:	BHEL-BCU Bay Control Unit	Optional Reservation Test:	No
HW Version:	2.0	Serial Number:	
SW Version:	2.0	Publisher Legacy Variants:	
Key Words:	Bay Controller	Publisher Preferred Rates:	
Test Procedure Version:	1.0	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Setting Group Definition (B4+), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	09/18/2018	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Central Power Research Institute India (A)		
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:53 PM - Herbert Falk

- File CPRI_BHEL-BCU_MUADSASL1718C003.pdf added

Files

CPRI_BHEL-BCU_MUADSASL1718C003.pdf

852 KB

07/08/2021

Herbert Falk