

# IEC 61850 Certificate - IEC 61850 Certificate #2775

## CU3000 Power Quality and Measurements IE [Camille Bauer Metrawatt AG]

07/08/2021 04:53 PM - Herbert Falk

<b>Status:</b>	Approved	<b>Test Document:</b>	
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	ZE 101466 001 R00 C
<b>61850 Edition:</b>	Edition 2	<b>Certificate Hash:</b>	C2E0A7445B8D663DD4B6F291258806 A588E969EF6B2E7FBE6B71CEBC1203 2D68
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	Camille Bauer Metrawatt AG	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	Aargauerstrasse 7 5610 Wohlen Switzerland	<b>Umbrella Organization:</b>	
<b>Product:</b>	CU3000 Power Quality and Measurements IE	<b>Optional Reservation Test:</b>	No
<b>HW Version:</b>		<b>Serial Number:</b>	
<b>SW Version:</b>	1.0	<b>Publisher Legacy Variants:</b>	
<b>Key Words:</b>	Meter	<b>Publisher Preferred Rates:</b>	
<b>Test Procedure Version:</b>	1.0	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Enhanced SBO Control (12d), Time Synchronization (B13), Unbuffered Reporting (B5)	<b>Subscriber Legacy Variants:</b>	
<b>Certificate/Result Reviewer:</b>	bruce.muschlitz	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	10/11/2018	<b>Subscriber Preferred Rates:</b>	
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	TUV SUD Germany (A)		

**Description**  
This certificate and its information was migrated from a previous database

### History

#1 - 07/08/2021 04:54 PM - Herbert Falk

- File UCA-ZE 101466 001 R00 C-Camille Bauer\_CU3000\_IEC61850Ed2-Server-Certif added

### Files

UCA-ZE 101466 001 R00 C-Camille Bauer\_CU3000\_IEC61850Ed2-Server-Certif.pdf 07/08/2021

Herbert Falk