

IEC 61850 Certificate - IEC 61850 Certificate #2776

CU5000 Power Quality and Measurements IE [Camille Bauer Metrawatt AG]

07/08/2021 04:54 PM - Herbert Falk

Status:	Approved	
Priority:	Normal	
61850 Edition:	Edition 2	Certificate Name: ZE 101466 001 R00 D
61850 Tested Aspects:	Server	Certificate Hash: 1CFDDE83C478D9BE9650F5E91CD1793EB78BBEE1ADF593F98618F731A5D8FC6F
Company:	Camille Bauer Metrawatt AG	Vendor Artifact File Name:
Address:	Aargauerstrasse 7 5610 Wohlen Switzerland	Vendor Artifact Hash:
Product:	CU5000 Power Quality and Measurements IE	Umbrella Organization:
HW Version:		Optional Reservation Test: No
SW Version:	1.0	Serial Number:
Key Words:	Meter	Publisher Legacy Variants:
Test Procedure Version:	1.0	Publisher Preferred Rates:
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Enhanced SBO Control (12d), Time Synchronization (B13), Unbuffered Reporting (B5)	Publisher Preferred Variants:
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Legacy Variants:
Approval Date:	10/11/2018	Subscriber Preferred Variants:
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	Subscriber Preferred Rates:
Current Test Lab Name:	TUV SUD Germany (A)	Product Variants:
Test Document:		Time Activated Control:
Description This certificate and its information was migrated from a previous database		

History

#1 - 07/08/2021 04:54 PM - Herbert Falk

- File UCA-ZE 101466 001 R00 D-Camille Bauer_CU5000_IEC61850Ed2-Server-Certif added

Files

UCA-ZE 101466 001 R00 D-Camille Bauer_CU5000_IEC61850Ed2-Server-Certif.pdf 07/08/2021

Herbert Falk