

IEC 61850 Certificate - IEC 61850 Certificate #2781

REX640 Protection and Control [ABB Oy]

07/08/2021 04:54 PM - Herbert Falk

Status:	Approved	
Priority:	Normal	
61850 Edition:	Edition 2	Certificate Name: 10096267-INC 18-2859
61850 Tested Aspects:	Server	Certificate Hash: 4033A9C41D66C7719BC7828799D4CD 293DD81915C9A7CF633982C9B6401D 7129
Company:	ABB Oy	Vendor Artifact File Name:
Address:	Distribution Solutions Muottitie 2 A FI-65101 Vaasa Finland	Vendor Artifact Hash:
Product:	REX640 Protection and Control	Umbrella Organization:
HW Version:		Optional Reservation Test: No
SW Version:	1.0	Serial Number:
Key Words:	Differential, Distance, Protection, Relay	Publisher Legacy Variants:
Test Procedure Version:	1.0	Publisher Preferred Rates:
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Setting Group (B4), Setting Group Definition (B4+), Time Synchronization (B13), Unbuffered Reporting (B5)	Publisher Preferred Variants:
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Legacy Variants:
Approval Date:	10/31/2018	Subscriber Preferred Variants:
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	Subscriber Preferred Rates:
Current Test Lab Name:	DNV Netherlands (A)	Product Variants:
Test Document:		Time Activated Control:
Description This certificate and its information was migrated from a previous database		

History

#1 - 07/08/2021 04:54 PM - Herbert Falk

- File 18-2859_DNVGL_ABB_REX640_ServerEd2_Certificate.pdf added

Files

18-2859_DNVGL_ABB_REX640_ServerEd2_Certificate.pdf	138 KB	07/08/2021	Herbert Falk
--	--------	------------	--------------