

IEC 61850 Certificate - IEC 61850 Certificate #2784

SITRAS MDC DC Protection Device [Siemens Mobility GmbH]

07/08/2021 04:54 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	ZE 092660 0002 R00
61850 Edition:	Edition 2	Certificate Hash:	EAF52FF71C7AF653F91A77AFFAD46A CB3C2E79B7C6950F2E1503B93082F6 9910
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Siemens Mobility GmbH	Vendor Artifact Hash:	
Address:	Mozartstrasse 33 B 91052 Erlangen Germany	Umbrella Organization:	
Product:	SITRAS MDC DC Protection Device	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	1.0.1	Publisher Legacy Variants:	
Key Words:	Protection, Relay	Publisher Preferred Rates:	
Test Procedure Version:	1.0	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	11/05/2018	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	TUV SUD Germany (A)		

Description
This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:54 PM - Herbert Falk

- File UCA_ZE 092660 0002 R00_Siemens_Sitras MDC_IEC61850Ed2-Server-Certifica added

Files

UCA_ZE 092660 0002 R00_Siemens_Sitras MDC_IEC61850Ed2-Server-Certifica.pdf 07/08/2021

Herbert Falk