

IEC 61850 Certificate - IEC 61850 Certificate #2785

DAONSYSA-SA-Gateway Substation Automation [DAONSYSA Limited Company]

07/08/2021 04:54 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	18-065505-01-2
61850 Edition:	Edition 1	Certificate Hash:	6FA450CF9AA7F23862A913DC6D4EC0 A5CE17F1AF74A21F2C243E0C0BAB95 5E2D
61850 Tested Aspects:	Client	Vendor Artifact File Name:	
Company:	DAONSYSA Limited Company	Vendor Artifact Hash:	
Address:	#1803, M-dong, 32, Songdogwahak-ro, Yeonsu-gu, Incheon, Republic of Korea, 21984	Umbrella Organization:	
Product:	DAONSYSA-SA-Gateway Substation Automation	Optional Reservation Test:	No
HW Version:	Window Server 2012 R2	Serial Number:	
SW Version:	1.0	Publisher Legacy Variants:	
Key Words:	Gateway	Publisher Preferred Rates:	
Test Procedure Version:	1.1	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), SBO Control (12b), Setting Group (B4), Setting Group Definition (B4+), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	11/06/2018	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Korea Testing Laboratory (A)		
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:54 PM - Herbert Falk

- File 18-065505-01-2_DAONSYSA-SA-Gateway_Client_Ed1_Certification_KTL.pdf added

Files

18-065505-01-2_DAONSYSA-SA-Gateway_Client_Ed1_Certification_KTL.pdf	112 KB	07/08/2021	Herbert Falk
---	--------	------------	--------------