

# IEC 61850 Certificate - IEC 61850 Certificate #2786

## DAONSYSA SA-HMI Substation Automation Ope [DAONSYSA Limited Company]

07/08/2021 04:54 PM - Herbert Falk

|  |  |                                       |  |
|--|--|---------------------------------------|--|
| <b>Status:</b>   | Approved   | <b>Test Document:</b>                 |  |
| <b>Priority:</b>   | Normal   | <b>Certificate Name:</b>              | 18-063957-01-1   |
| <b>61850 Edition:</b>  | Edition 1  | <b>Certificate Hash:</b>              | 05860BDA92D416BD516E8D184107A7<br>AF1D61E5FB480A62EE0CB280973F4E<br>DBCB |
| <b>61850 Tested Aspects:</b>   | Client   | <b>Vendor Artifact File Name:</b>     |  |
| <b>Company:</b>  | DAONSYSA Limited Company   | <b>Vendor Artifact Hash:</b>          |  |
| <b>Address:</b>  | #1803, M-dong, 32, Songdogwahak-ro,<br>Yeonsu-gu, Incheon,<br>Republic of Korea, 21984   | <b>Umbrella Organization:</b>         |  |
| <b>Product:</b>  | DAONSYSA SA-HMI Substation<br>Automation Ope   | <b>Optional Reservation Test:</b>     | No   |
| <b>HW Version:</b>   | Window Server 2012 R2  | <b>Serial Number:</b>                 |  |
| <b>SW Version:</b>   | 1.0  | <b>Publisher Legacy Variants:</b>     |  |
| <b>Key Words:</b>  | HMI  | <b>Publisher Preferred Rates:</b>     |  |
| <b>Test Procedure Version:</b>   | 1.1  | <b>Publisher Preferred Variants:</b>  |  |
| <b>IEC 61850 Blocks Certified:</b>   | Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), SBO Control (12b), Setting Group (B4), Setting Group Definition (B4+), Time Synchronization (B13), Unbuffered Reporting (B5) | <b>Subscriber Legacy Variants:</b>    |  |
| <b>Certificate/Result Reviewer:</b>  | bruce.muschlitz  | <b>Subscriber Preferred Variants:</b> |  |
| <b>Approval Date:</b>  | 11/06/2018   | <b>Subscriber Preferred Rates:</b>    |  |
| <b>Standards Tested:</b>   | 61850-6, 61850-7-1, 61850-7-2,<br>61850-7-3, 61850-7-4, 61850-8-1  |                                       |  |
| <b>Current Test Lab Name:</b>  | Korea Testing Laboratory (A)   |                                       |  |
| <b>Description</b>   |  |                                       |  |
| This certificate and its information was migrated from a previous database |  |                                       |  |

### History

#1 - 07/08/2021 04:54 PM - Herbert Falk

- File 18-063957-01-1\_DAONSYSA\_SA-HMI\_Client\_Ed1\_Certification\_KTL.pdf added

### Files

18-063957-01-1\_DAONSYSA\_SA-HMI\_Client\_Ed1\_Certification\_KTL.pdf 23 KB

07/08/2021

Herbert Falk