

IEC 61850 Certificate - IEC 61850 Certificate #2787

GRZ200 Distance Protection [TOSHIBA Corporation]

07/08/2021 04:54 PM - Herbert Falk

Status:	Approved	
Priority:	Normal	
61850 Edition:	Edition 2	Certificate Name: 10120137-INC 18-2985
61850 Tested Aspects:	Server	Certificate Hash: FFC03DC29E0C42C1E5A401751838490B620F28D82563ABD36150AA8A74DFBD67
Company:	TOSHIBA Corporation	Vendor Artifact File Name:
Address:	Fuchu Complex 1, TOSHIBA-Cho Fuchu-shi, Tokyo, 183-8511 Japan	Vendor Artifact Hash:
Product:	GRZ200 Distance Protection	Umbrella Organization:
HW Version:	GRZ200-11-228-00-1J-30-210	Optional Reservation Test: No
SW Version:	GS2RLIM13Y00, 61850=G2M85002A	Serial Number:
Key Words:	Distance, Protection, Relay	Publisher Legacy Variants:
Test Procedure Version:	1.0	Publisher Preferred Rates:
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Service Tracking (B15), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Publisher Preferred Variants:
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Legacy Variants:
Approval Date:	11/06/2018	Subscriber Preferred Variants:
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	Subscriber Preferred Rates:
Current Test Lab Name:	DNV Netherlands (A)	Product Variants:
Test Document:		Time Activated Control:
Description This certificate and its information was migrated from a previous database		

History

#1 - 07/08/2021 04:54 PM - Herbert Falk

- File 18-2985_DNVGL_TOSHIBA_GRZ200_ServerEd2_Certificate.pdf added

Files

18-2985_DNVGL_TOSHIBA_GRZ200_ServerEd2_Certificate.pdf	140 KB	07/08/2021	Herbert Falk
--	--------	------------	--------------