

IEC 61850 Certificate - IEC 61850 Certificate #2788

GRD200 Multi Function Protection [TOSHIBA Corporation]

07/08/2021 04:54 PM - Herbert Falk

| | | | |
|-------------------------------------|---|---------------------------------------|--|
| Status: | Approved | Certificate Name: | 10120137-INC 18-2988 |
| Priority: | Normal | Certificate Hash: | 8067730060AC02ACDABBB3DF6C46D B94368FC5282D1C33ACFD3AEEC073 BA5075 |
| 61850 Edition: | Edition 2 | Vendor Artifact File Name: | |
| 61850 Tested Aspects: | Server | Vendor Artifact Hash: | |
| Company: | TOSHIBA Corporation | Umbrella Organization: | |
| Address: | Power Systems Protection and Control Fuchu Complex 1, TOSHIBA-Cho Fuchu-shi, Tokyo, 183-8511 Japan | Optional Reservation Test: | No |
| Product: | GRD200 Multi Function Protection | Serial Number: | |
| HW Version: | GRD200-41-228-00-1J-30-210 | Publisher Legacy Variants: | |
| SW Version: | GS2RDIM13X00, 61850=G2M85002A | Publisher Preferred Rates: | |
| Key Words: | IOC, Protection, Relay, TOC | Publisher Preferred Variants: | |
| Test Procedure Version: | 1.0 | Subscriber Legacy Variants: | |
| IEC 61850 Blocks Certified: | Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Service Tracking (B15), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5) | Subscriber Preferred Variants: | |
| Certificate/Result Reviewer: | bruce.muschlitz | Subscriber Preferred Rates: | |
| Approval Date: | 11/06/2018 | Product Variants: | |
| Standards Tested: | 61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1 | | |
| Current Test Lab Name: | DNV Netherlands (A) | | |
| Test Document: | | | |

Description
This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:54 PM - Herbert Falk

- File 18-2988_DNVGL_TOSHIBA_GRD200_ServerEd2_Certificate.pdf added

Files

| | | | |
|--|--------|------------|--------------|
| 18-2988_DNVGL_TOSHIBA_GRD200_ServerEd2_Certificate.pdf | 139 KB | 07/08/2021 | Herbert Falk |
|--|--------|------------|--------------|