

# IEC 61850 Certificate - IEC 61850 Certificate #2791

## SEL-487E Transformer Protection Relay [Schweitzer Engineering Laboratories, Inc.]

07/08/2021 04:54 PM - Herbert Falk

<b>Status:</b>	Approved	<b>Test Document:</b>	
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	10117109-INC 18-3067
<b>61850 Edition:</b>	Edition 2	<b>Certificate Hash:</b>	CD5CB1023996544B3B7C4194D6DB3A 8473BCCDC908E81DC427B008DBB0F 0965C
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	Schweitzer Engineering Laboratories, Inc.	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	2350 NE Hopkins Court Pullman, WA 99163-5603 USA	<b>Umbrella Organization:</b>	
<b>Product:</b>	SEL-487E Transformer Protection Relay	<b>Optional Reservation Test:</b>	No
<b>HW Version:</b>		<b>Serial Number:</b>	
<b>SW Version:</b>	R400-V0-D20180910; lib=99D375289	<b>Publisher Legacy Variants:</b>	
<b>Key Words:</b>	Differential, Protection, Relay	<b>Publisher Preferred Rates:</b>	
<b>Test Procedure Version:</b>	1.0	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	<b>Subscriber Legacy Variants:</b>	
<b>Certificate/Result Reviewer:</b>	bruce.muschlitz	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	11/26/2018	<b>Subscriber Preferred Rates:</b>	
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	DNV Netherlands (A)		

### Description

This certificate and its information was migrated from a previous database

### History

#1 - 07/08/2021 04:54 PM - Herbert Falk

- File 18-3067\_DNVGL\_SEL\_SEL-487E-487B-451\_ServerEd2\_Certificate.pdf added

#2 - 07/09/2021 08:01 AM - Herbert Falk

- Umbrella Organization set to Schneider Electric

#3 - 07/09/2021 09:10 AM - Herbert Falk

- Umbrella Organization deleted (Schneider Electric)

### Files

18-3067\_DNVGL\_SEL\_SEL-487E-487B-451\_ServerEd2\_Certificate.pdf 34 KB

07/08/2021

Herbert Falk