

IEC 61850 Certificate - IEC 61850 Certificate #2794

NSR-3611 Feeder Protection [NARI Technology Co., Ltd.]

07/08/2021 04:54 PM - Herbert Falk

Status:	Approved	Certificate Name:	10122257-INC 18-3158
Priority:	Normal	Certificate Hash:	C3525879B4CC09EB9D7988B4E3ECA 4F8F7BB9EF09EA4F12A22505401294F A527
61850 Edition:	Edition 2	Vendor Artifact File Name:	
61850 Tested Aspects:	Server	Vendor Artifact Hash:	
Company:	NARI Technology Co., Ltd.	Umbrella Organization:	
Address:	NARI Technology CO., Ltd. No.19, Chengxin Avenue, Jiangning District, 210000, Nanjing, People's Republic of China	Optional Reservation Test:	No
Product:	NSR-3611 Feeder Protection	Serial Number:	
HW Version:	R1.30	Publisher Legacy Variants:	
SW Version:	6.03	Publisher Preferred Rates:	
Key Words:	Protection, Relay	Publisher Preferred Variants:	
Test Procedure Version:	1.0	Subscriber Legacy Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), Setting Group (B4), Setting Group Definition (B4+), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Preferred Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Rates:	
Approval Date:	12/13/2018	Product Variants:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Test Document:			
Description This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:54 PM - Herbert Falk

- File 18-3158_DNVGL_NARI_TECH_NSR3611_plus_Variants_ServerEd2_Certificate.pdf added

Files

18-3158_DNVGL_NARI_TECH_NSR3611_plus_Variants_ServerEd2_Certificate.pdf 07/08/2021

Herbert Falk