

IEC 61850 Certificate - IEC 61850 Certificate #2796

ADR245B Modular Version Directional Feed [Ashida Electronics Pvt. Ltd.]

07/08/2021 04:54 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	10119305_INC 18-2968
61850 Edition:	Edition 2	Certificate Hash:	A8DE43F315E28C1C08ECC6FE89AA6 EB4B91DDA8B77ED5D79214745B189A 4D6FA
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Ashida Electronics Pvt. Ltd.	Vendor Artifact Hash:	
Address:	Plot No. A308, Road No. 21, Wagle Industrial Estate, Thane 400604, Mumbai India	Umbrella Organization:	
Product:	ADR245B Modular Version Directional Feed	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	2.2.0	Publisher Legacy Variants:	
Key Words:	Protection, Relay	Publisher Preferred Rates:	
Test Procedure Version:	1.0	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	12/20/2018	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:54 PM - Herbert Falk

- File 18-2968_DNVGL_ASHIDA_ADR245B_variants_ServerEd2_Certificate.pdf added

Files

18-2968_DNVGL_ASHIDA_ADR245B_variants_ServerEd2_Certificate.pdf 104 KB

07/08/2021

Herbert Falk