

IEC 61850 Certificate - IEC 61850 Certificate #2797

RC-10 Recloser Controller and Communic [NOJA Power Switchgear Pty Ltd]

07/08/2021 04:54 PM - Herbert Falk

Status:	Approved	Certificate Name:	ZE 10276 0001 R00
Priority:	Normal	Certificate Hash:	0488868E5C1026AB91277B62768E4EB 5057431435D499322EF2378AC2B1636 66
61850 Edition:	Edition 1	Vendor Artifact File Name:	
61850 Tested Aspects:	Server	Vendor Artifact Hash:	
Company:	NOJA Power Switchgear Pty Ltd	Umbrella Organization:	
Address:	16 Archimedes Place BRISBANE OLD 4172 Australia	Optional Reservation Test:	No
Product:	RC-10 Recloser Controller and Communic	Serial Number:	
HW Version:		Publisher Legacy Variants:	
SW Version:	1.22.0.0	Publisher Preferred Rates:	
Key Words:	Comm	Publisher Preferred Variants:	
Test Procedure Version:	3.2	Subscriber Legacy Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Preferred Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Rates:	
Approval Date:	01/08/2019	Product Variants:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	TUV SUD Germany (A)		
Test Document:			
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:54 PM - Herbert Falk

- File UCA-ZE 10276 0001 Rev00-NOJApower_RC-10_IEC61850Ed2-Server-Certificate added

Files

UCA-ZE 10276 0001 Rev00-NOJApower_RC-10_IEC61850Ed2-Server-Certificate_V2.07/08/2021

Herbert Falk