IEC 61850 Certificate - IEC 61850 Certificate #2799

DW-SPiN-ICM Protocol Converter [Daewoong Electric Co. Ltd.]

07/08/2021 04:54 PM - Herbert Falk

Status:	Approved		
Priority:	Normal		
61850 Edition:	Edition 1	**Certificate Name:**	2019TS00008
61850 Tested Aspects:	Server	**Certificate Hash:**	857A01F1044AEF7708ED890BCF0FC9F41E686832AF3E1486E6DAE98A83096225
Company:	Daewoong Electric Co. Ltd.	**Vendor Artifact File Name:**	
Address:	10, Hwanggeum-ro 127beon-gil, Yangchon-eup. Gimpo-si, Gyeonggi-do, Republic of Korea, 10048	**Vendor Artifact Hash:**	
Product:	DW-SPiN-ICM Protocol Converter	**Umbrella Organization:**	
HW Version:		**Optional Reservation Test:**	No
SW Version:	1.0	**Serial Number:**	
Key Words:	Comm, Gateway	**Publisher Legacy Variants:**	
Test Procedure Version:	3.2	**Publisher Preferred Rates:**	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Time Synchronization (B13), Unbuffered Reporting (B5)	**Publisher Preferred Variants:**	
Certificate/Result Reviewer:	bruce.muschlitz	**Subscriber Legacy Variants:**	
Approval Date:	01/17/2019	**Subscriber Preferred Variants:**	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	**Subscriber Preferred Rates:**	
Current Test Lab Name:	Korea Electrotechnology Research Institute (A)	**Product Variants:**	
Test Document:			

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:54 PM - Herbert Falk

- File 2019TS00008_Daewoong_DW-SPiN-ICM_Server1.0_KERI.pdf added

Files

2019TS00008_Daewoong_DW-SPiN-ICM_Server1.0_KERI.pdf	4.57 MB	07/08/2021	Herbert Falk